

METHOD #5 PARALLEL (2P) HIGH LOW SYSTEM

**NOTE: FOR BI-METAL VALVES ONLY
INCLUDING TYPE TM SERIES**



SEE INSTALLATION
INSTRUCTIONS FOR VALVE
SPECIFIC PIPING DIAGRAMS AND
SET UP PROCEDURE.

FOR MULTIPLE TEMPERED
LOOPS A BALANCING VALVE AND
CHECK VALVE MUST BE
INSTALLED ON EACH LOOP
AFTER TEMPERED FIXTURES.

